



DIVISION 23 - Heating, Ventilating, and Air-Conditioning (HVAC)
23 21 00 - Hydronic Piping and Pumps
23 21 23 - Hydronic Pumps

PART 1 - GENERAL

1.01 DESCRIPTION OF WORK

- A. Provide pumps and required system trim for heating, chilled water, and dual temperature water systems including all related appurtenances for a complete and operating system.

1.02 SECTION INCLUDES

- A. Close Coupled, Vertical Twin Pump

1.03 RELATED SECTIONS

- A. Drawings and general provisions of the contract, including general and supplementary Conditions and Division 1 Specification Sections, apply to these Sections:

- Section *** - Alignment of Rotating Equipment
- Section *** - Cast-in-Place Concrete
- Section *** - Mechanical General Requirements
- Section *** - Supports, Anchors, and Sleeves
- Section *** - Motors and Starters
- Section *** - Drives
- Section *** - Mechanical Identification
- Section *** - Vibration Isolation
- Section *** - Piping Insulation
- Section *** - Equipment Installation
- Section *** - Hydronic Piping and Specialties
- Section *** - Testing, Adjusting, and Balancing
- Section *** - Meters and Gauges
- Section *** - Electrical

1.04 REFERENCES

- A. HI - Hydraulic Institute.
B. ANSI - American National Standards Institute.
C. OSHA - Occupational Safety & Health Administration.
D. ASHRAE - American Society of Heating, Refrigeration and Air-Conditioning Engineers.
E. NEMA - National Electrical Manufacturers Association.
F. UL - Underwriters Laboratories.

- G. ETL - Electrical Testing Laboratories.
- H. CSA - Canadian Standards Association.
- I. NEC - National Electric Codes.
- J. ISO - International Standards Organization.
- K. IEC - International Electrotechnical Commission.
- L. ASME - American Society of Mechanical Engineers.

1.05 SUBMITTAL

- A. Submit each item in this article according to the Conditions of the Contract and Division 1 Specification Sections.
- B. Submit manufacturer's installation instructions under provisions of General Conditions and Division 1.
- C. Operation and Maintenance Data: Include installation instructions, assembly views, lubrication instructions, and replacement parts lists.
- D. Under provisions of commissioning documentation, testing of pumps, as well as training of owner's operation and maintenance personnel may be required in cooperation with the commissioning consultant.
- E. Product Data including certified performance curves and rated capacities of selected model, weights (shipping, installed, and operating), furnished specialties, and accessories. Indicate pump's operating point on curves.
- F. Complete Package information Product Data including:
 - System summary sheet (where applicable)
 - Sequence of Operation
 - Shop drawing indicating dimensions, required clearances and location and size of each field connection
 - Power and control wiring diagram
 - System profile analysis including pump curves, system curve, and variable speed pump curves (where applicable)
 - Pump data sheets - Rated capacities of selected models and indication of pump's operating point on curves.
 - Submittals on furnished specialties and accessories
 - Submittals must be specific to this project. Generic submittals will not be accepted.
- G. A detailed weighted average pump efficiency-Part Load Efficiency Value (PLEV) - Pump Rating Report shall be submitted for each pump. Pump PLEV shall be based on the standard load profile developed in AHRI 550/590-1998 also known as IPLV or Integrated Part Load Value. The pump PLEV Rating shall be based points A: 100%, B: 75%, C: 50% and D: 25% with each Pump Efficiency ratings shown with flow matched to load percentage and Specified Control Head.
- H. Specified Control Head shall be 30% TDH or calculated minimum control head specified within the equipment schedule
- I. Pump PLEV shall be expressed with load weighting Pump PLEV = $1 / (0.01/A+0.42/B+0.45/C+0.12/D)$ where
 - A = Pump Efficiency at 100%
 - B = Pump Efficiency at 75%
 - C = Pump Efficiency at 50%
 - D = Pump Efficiency at 25%
 Actual job specific load profile weighting may be substituted for standard IPLV weighting

- J. Hanging and support requirements should follow the recommendations in the manufacturer's installation instructions.
- K. Submittals that are "rejected" as being "non-compliant" will be re-reviewed once with all time for subsequent reviews back charged to the contractor in accordance with the engineer's current prevailing rate schedule. If a rate schedule for additional services is included, as part of the contract with the owner that rate schedule shall be used in lieu of the "current prevailing" rate schedule.

1.06 QUALITY ASSURANCE

- A. All equipment or components of this specification section shall meet or exceed the requirements and quality of the items herein specified, or as denoted on the drawings.
- B. Ensure pump operation, at specified system fluid temperatures without vapor binding and cavitation, is non-overloading in parallel or individual operation, and operates to ANSI/HI 9.6.3.1 standard for Preferred Operating Region (POR) unless otherwise approved by the engineer.
- C. Ensure pump pressure ratings are at least equal to system's maximum operating pressure at point where installed but not less than specified.
- D. Equipment manufacturer shall be a company specializing in manufacture, assembly, and field performance of provided equipment with a minimum of 20 years experience.
- E. Equipment provider shall be responsible for providing certified equipment start-up and, when noted, an in the field certified training session. New pump start-up shall be for the purpose of determining pump alignment, lubrication, voltage, and amperage readings. All proper electrical connections, pump's balance, discharge and suction gauge readings, and adjustment of head, if required. A copy of the start-up report shall be made and sent to both the contractor and to the Engineer.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials to the site in such a manner as to protect the materials from shipping and handling damage. Provide materials on factory provided shipping skids and lifting lugs if required for handling. Materials damaged by the elements should be packaged in such a manner that they could withstand short-term exposure to the elements during transportation.
- B. Store materials in clean, dry place and protect from weather and construction traffic. Handle carefully to avoid damage.
- C. Use all means necessary to protect equipment before, during, and after installation.
- D. All scratched, dented, and otherwise damaged units shall be repaired or replaced as directed by the Architect Engineer.

1.08 WARRANTY:

- A. Provide a minimum One (1) year warranty on materials and installation under provision of Section 01 78 36

PART 2 – PRODUCTS**2.01 MANUFACTURERS**

- A. The specifying engineer reserves the right to specify a primary supplier / lead spec manufacturer on all supplied schedule and specification documents. These primary suppliers have led their respective industry in research and development and their products have had proven track records in the field. These primary suppliers, in the opinion of this engineering firm, produce a superior product to the alternately listed manufacturers. The contractor may choose to supply equivalent equipment as manufactured by the alternately specified manufacturer. This alternately specified equipment shall be supplied on a deduct alternate basis and based on the approval of the supplied alternate manufacturer's submittals. The use of a primary supplier and deduct alternates protects the specifying engineer's design concept, but allows for a check-and-balance system to protect the post-commissioning owner.
- B. Contractor shall furnish and install new close-coupled vertical inline twin pump for chilled water and hot water heating systems as indicated on the drawings. Pumps shall be Series e-82 as manufactured by **Bell & Gossett** under base bid. Equivalent units as manufactured by other manufacturers may be submitted as deduct alternates. Pumps shall meet types, sizes, capacities, and characteristics as scheduled on the Equipment Schedule drawings. Pump substitutions shall be provided with connection sizes equal to those scheduled. Pump connections shall not be downsized. Pump substitutions shall not be provided at efficiencies less than those scheduled.

2.02 COMPONENTS

- A. The pumps shall be close-coupled, inline for vertical or horizontal installation, in cast iron or ductile iron stainless steel fitted construction specifically designed for quiet operation. Suitable standard operations at 225°F and 175 PSIG working pressure. Working pressures shall not be de-rated at temperatures up to 250°F. The pump internals shall be capable of being serviced without disturbing piping connections.
- B. The pumps shall have a solid alloy steel shaft that is integral to the motor. A non-ferrous shaft sleeve shall be employed to completely cover the wetted area under the seal.
- C. The motor bearings shall support the shaft via heavy-duty grease lubricated ball bearings.
- D. Pump shall be equipped with an internally flushed mechanical seal assembly installed in an enlarged tapered seal chamber. Seal assembly shall have a stainless steel housing, Buna bellows and seat gasket, stainless steel spring, and be of a carbon ceramic design with the carbon face rotating against a stationary ceramic face. (As an option, a stuffing box designed may be used in lieu of the traditional internally flushed mechanical seal design in which case pump shall be equipped with flushed single seals, flushed double seals, or packing gland type seal arrangements.)
- E. As an option an EPR/Carbon/Tungsten/Carbide/SS seal (250°F maximum operating temperature), FKM/Carbon/Ceramic/SS seal, or EPR-Silicon Carbide/Silicon Carbide/SS seal may be used in lieu of the standard Buna/Carbon/Ceramic/SS seal (225° F maximum operating temperature).
- F. Pump shaft shall connect to stainless steel impellers. Impellers shall be hydraulically and dynamically balanced to Hydraulic Institute Standards ANSI/HI 9.6.4.-2016. The allowable residual imbalance conforms to ANSI grade G6.3, keyed to the shaft and secured by a stainless steel locking capscrew or nut.
- G. Pump should be designed to allow for true back pull-out access to the pump's working components for ease of maintenance.
- H. Pump volute shall be of a Class 30B cast iron design or Grade 65:45:12 ductile iron design for heating systems rated for 175 PSIG with integral cast iron flanges drilled for 125# ANSI companion flanges. Volute shall include gauge ports at nozzles, and vent and drain ports. The volute shall be designed with a base ring matching an ANSI 125# flange that can be used for pump support.

- I. Self-balancing flapper valve shall be 316 stainless steel with EPDM gasket. Valve shall be mounted into the pump volute using self-sealing bolts.
- J. Motors shall be NEMA Premium efficient and shall be the size, voltage, and enclosure called for on the plans. Motors shall have heavy-duty grease lubricated ball bearings to offset the additional bearing loads associated with closed coupled design. Motors shall be non-overloading at any point on the pump curve and shall meet NEMA specifications.
- K. Pumps shall conform to ANSI/HI 9.6.3.1-2012 standard for Preferred Operating Region (POR) unless otherwise approved by the engineer.
- L. Pump shall be of a maintainable design and for ease of maintenance should use machine fit parts and not press fit components.
- M. Pump manufacturer shall be ISO-9001 certified.
- N. Each pump shall be factory tested and name-plated before shipment.
- O. As an option, the pump may include an internal stainless steel casing wear rings.
- P. Where noted on schedule pumping equipment may require one or all of the following optional tests: Certified Lab tests (unwitnessed), Hydraulic Institute Level B tests, or Witnessed Tests.

2.03 ACCESSORIES

- A. Where noted on the schedule, provide two mechanical seals for each model type of primary pump.
- B. Where noted on schedule a Bell & Gossett Sediment Separator shall be furnished for installation on the flushing line between the pump discharge flange and the seal area. The sediment separator is installed to increase the overall life expectancy of the seal on inherently dirty systems. The separator shall remove dissolved solids from the flushing medium before the fluid enters the seal area where it can damage and shorten the life of the seal.
- C. Where noted on schedule a Bell & Gossett Brazed Plate Heat Exchanger Kit shall be furnished for installation on the flushing line between the pump discharge flange and the seal area. The heat exchanger is installed to increase the overall life expectancy of the seal on high temperature systems (greater than 225° F). The kit shall decrease the temperature of the flushing water being provided to the seal area as a flushing medium to a temperature less than 225° F. Flushing temperatures higher than 225° F can damage and shorten the life of the seal.

2.04 INTEGRATED VFD WITH SENSORLESS PUMP CONTROL

- A. Integrated Pump Controllers shall be factory mounted, wired, with a mains disconnect switch and menu-driven graphical interface.
- B. Integrated Pump Controllers shall provide near unity displacement power factor (cos Ø) without need for external power factor correction capacitors at all loads and speeds using VVC-PWM type integrated controls.
- C. Integrated Pump Controllers shall include dual DC link reactors equivalent to 5% impedance line reactors, for reduction of mains borne harmonic currents and DC link ripple current to increase DC link capacitor lifetime.
- D. Integrated Pump Controllers shall have EMI/RFI filters conforming to DIN EN61800-3 to ensure integrated controls meets low emission and immunity requirements.
- E. System pressure to be maintained: [_____] feet head minimum.
- F. Integrated Pump Controllers' orientation combination shall be specified as [VL1], [VL2], [VL3], [VL4]
- G. Integrated Pump Controllers shall support direct communication with the building management system (BMS) with built-in support for the following protocols: [Modbus RTU] [BACnet™ MS/TP] [Metasys N2]

- H. Integrated Pump Controllers shall be provided in an Enclosure rated to UL Type 12 suitable for indoor operation.
- I. Integrated Pump Controllers shall support Programmable skip Frequencies and adjustable switching frequency for noise and vibration control.
- J. Integrated Pump Controllers shall provide a temperature controlled Fan for cooling of the heat sink in the back panel.
- K. Integrated Pump Controllers shall be rated to operate in ambient working conditions of [14°F to +113°F], up to [3300] feet above sea level.
- L. Integrated Pump Controllers shall provide 2 Analog inputs (current or voltage) and 1 current output.
- M. Integrated Pump Controllers shall provide 6 programmable Digital inputs with 2 configurable as outputs.
- N. Integrated Pump Controllers shall support 2 programmable pulse inputs
- O. Integrated Pump Controllers shall provide 2 programmable relay outputs
- P. Integrated Pump Controllers shall provide 1 RS485 communication port
- Q. Integrated Pump Controllers system software shall be capable of sensorless control in variable volume systems without need for pump mounted (internal/external) or remotely mounted differential pressure sensor.
- R. Integrated Pump Controllers Sensorless control shall operate under Quadratic Pressure Control (QPC) to ensure head reduction with reducing flow conforms to quadratic control curve.
- S. Integrated Pump Controllers shall support a minimum head of 40% of design duty head.
- T. Integrated Pump Controllers shall provide user adjustable control mode settings and minimum/maximum head set points using built-in programming interface.
- U. Integrated Pump Controllers integrated control software shall be capable of controlling pump performance for non-overloading power at every point of operation.
- V. Integrated Pump Controllers integrated control software shall be capable of maintaining flow rate data.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Install equipment in accordance with manufacturer's instructions.
- B. Reduction from line size to pump connection size shall be made with eccentric reducers attached to the pump with tops flat to allow continuity of flow.
- C. Furnish and install triple duty valves on the discharge side of all pumps and furnish and install a line size shut-off valve on the suction side of all pumps. Anywhere that 5 straight pipe diameters of pipe cannot be provided on the inlet side of a pump a suction diffuser shall be used to provide appropriate flow distribution into the eye of the pump's impeller.
- D. Provide temperature and pressure gauges where and as detailed or directed.
- E. On systems where pump seals require flushing water or cooling water for a heat exchanger kit, provide cooling water supply piping and connections as well as the return piping, if required. Piping should be of adequate size to pass required flow rate.
- F. Proper access space around a device should be left for servicing the component. No less than the minimum recommended by the manufacturer.
- G. Provide an adequate number of isolation valves for service and maintenance of the system and its components.

- H. Circulating pump shall have sufficient capacity to circulate the scheduled GPM against the scheduled external head (feet) with the horsepower and speed as scheduled and/or as denoted on the drawings. Motors shall be of electrical characteristics as scheduled, denoted and/or as indicated on the electrical plans and specifications. Pump characteristics shall be such that the head of the pump under varying conditions shall not exceed the rated horsepower of the drive motor.
- I. On systems where the final balancing procedure requires the triple duty valve to be throttled more than 25% to attain design flow (on a constant speed pumping system), and no future capacity has been built into the pump, the pump impeller must be trimmed to represent actual system head resistance. The pump provider and engineer of record, based on the balancing contractor's reports, shall determine the final impeller trim diameter.
- J. All piping shall be brought to equipment and pump connections in such a manner so as to prevent the possibility of any loads or stresses being applied to the connections or piping. All piping shall be fitted to the pumps even though piping adjustments may be required after the pipe is installed.
- K. On components that require draining, contractor must provide piping to and discharging into appropriate drains.
- L. Power wiring, as required, shall be the responsibility of the electrical contractor. All wiring shall be performed per manufacturer's instruction and applicable state, federal, and local codes.
- M. Control wiring for remote mounted switches and sensor / transmitters shall be the responsibility of the control's contractor. All wiring shall be performed per manufacturer's instructions and applicable state, federal, and local codes.

END OF SECTION

Xylem Inc.
2881 East Bayard Street Ext., Suite A
Seneca Falls, NY 13148
Phone: (844) XYL-PUMP [844-995-7867]
Fax: (888) 322-5877
www.xylem.com/bellgossett

Bell & Gossett is a trademark of Xylem Inc. or one of its subsidiaries.
© 2020 Xylem Inc. e-82SPECS R1 July 2020